Product Specification of:

Scuba Diving Oxygen Sensor

Type: D-10

Part Number: 410060


RoHS compliant by exemption, SVHC: lead

Produced under EN ISO 13485 Quality Management System

DOCUMENT PURPOSE

The purpose of this document is to present the performance specification and key features of the sensor.

This document should be used in conjunction with the Operating Manual of the instrument and the Product Safety Data Sheet of the sensor.



KEY FEATURES

Galvanic gas sensor for diving applications.

- **High Signal Stability**
- **Superior Linearity**
- **Wide Measurement Range**
- **Low Cross-Sensitivities**

IT Dr. Gambert GmbH .: Hinter dem Chor 21 .: 23966 Wismar .: Germany

Phone: +49 (0)3841 220 050 .: Fax: +49 (0)3841 220 052 2 .: E-Mail: info@itg-wismar.de **www.itg-wismar.de**

TECHNICAL SPECIFICATIONS

MEASUREMENT

Operating Principle:	Partial pressure electrochemical cell	
Measurement Range:	0 ... 100 Vol.% O_2	
Initial Output Signal:	22 ... 28 mV	at dry ambient air
Response Time t90:	< 15 s	
Signal Drift (long-term):	≤ ± 1 Vol.% O_2 / month	at air, averaged across 12 months, depending on application
Linearity Error:	≤ ± 3 %	at 100 Vol.% O_2 applied for 5 min
Zero Signal Offset:	≤ 150 µV	at 100 Vol.% N_2 applied for 5 min
Influence of Gas Humidity:	- 0.03 % rel. of signal per %rH	
Signal Temperature Compensation:	NTC on PCB	
Cross-Sensitivity:	none to He, H_2 and CO	

ELECTRICAL

Electrical Connector:	Winchester SM2S on wires
Recommended Load Resistor:	> 10 kOhm

MECHANICAL

Weight:	≤ 52 g
Material in Contact with Media:	ABS, PTFE, PPS, Stainless Steel
Gas Connector:	none

ENVIRONMENTAL

Operating Temperature Range:	10 ... 45 °C
Ambient Pressure Range:	600 ... 1750 hPa
Ambient Humidity Range:	up to 100 %rH

LIFETIME including shelf life

Nominal Sensor Life:	500 000 Vol.%h O_2	at ambient air, depending on application

Important Note: All characteristics are based on conditions at 25 °C, 50 %rH, 1013 hPa and a gas flow of > 2.5 l_S/min. For sensor performance data under other conditions, contact ITG.

IT Dr. Gambert GmbH .: Hinter dem Chor 21 .: 23966 Wismar .: Germany
Phone: +49 (0)3841 220 050 .: Fax: +49 (0)3841 220 052 2 .: E-Mail: info@itg-wismar.de **www.itg-wismar.de**

STORAGE CONDITIONS IN UNOPENED ORIGINAL PACKAGE

Ambient Temperature Range:	15 ... 25 °C	recommended
	-20 ... 50 °C	maximum (≤ 10 h)
Ambient Pressure Range:	600 ... 1750 hPa	
Ambient Humidity Range:	50 ... 100 %rH	recommended, non-condensing
	0 ... 30 %rH	maximum one week

RELATED PRODUCTS

Product	Part Number	Other Specifics
O_2-Sensor D-10	41 00 60	--

Installation in Device

Don`t use any mechanical tools to install the sensor. Using excessive force may damage the sensor.

Optimal mounting position of the sensor is when the gas sensing area faces downwards. A horizontal position is acceptable. It is not recommended to use the sensor with the gas sensing area facing upward.

Connection should be made via recommended electrical and mechanical connectors only. The specified load resistance must be taken into account. Soldering the sensor will damage it and void the warranty. Please contact ITG for further information.

Since temperature has an influence on the output signal it is not advisable to place any heat or vibration sources (i.e. electric-pumps or valves, coolers, etc.) in close proximity to the cell.

Avoid proximity of the cell to any EMC radiating units as those emit frequencies which might interfere with the sensor`s electrical connection and connecting cable.

Cleaning and Disinfection

The sensor outer housing can be cleaned with a dry wipe. Do not wipe the sensor`s gas entrance side. Do not use any chemical disinfectant or sanitizer on the sensor.

Poisoning

ITG sensors are designed to operate in a wide range of environments. For optimal sensor lifetime and performance it is important that exposure to high concentrations of solvent vapors is avoided during storage, installation into instruments and operation of the sensor.

Do not use adhesives directly on or near the sensor as the solvents may cause stress corrosion on the plastic parts.

Stabilization Time

When installing a new sensor refer to the instrument manual for stabilization time before calibration.

If not specified otherwise wait at least 15 minutes to ensure that the sensor has stabilized in the instrument.

Calibration Interval

ITG sensors are designed to have minimal signal drift over their functional lifetime. For optimal performance and maximum measurement accuracy however they should be calibrated before each use.

IT Dr. Gambert GmbH .: Hinter dem Chor 21 .: 23966 Wismar .: Germany
Phone: +49 (0)3841 220 050 .: Fax: +49 (0)3841 220 052 2 .: E-Mail: info@itg-wismar.de **www.itg-wismar.de**

If the Sensor is dropped

If a sensor is dropped, please check for visible mechanical damage of the sensor or if the sensor is leaking electrolyte. If this is the case, do not try to install the sensor into the device. Take safety precautions and immediately dispose the cell.

If the sensor shows no visible damage it should be placed in quarantine for at least 24 hours. Afterwards a follow-up check made by a two point calibration should be done.


Disposal


At the end of the sensors lifetime the sensor should not be disposed of in normal public waste as it may contain hazardous materials and caustic electrolyte (for more information refer to the PSDS). Please contact your local authorities for environmental legislation to relevant local waste disposal.

IT Dr. Gambert GmbH .: Hinter dem Chor 21 .: 23966 Wismar .: Germany
Phone: +49 (0)3841 220 050 .: Fax: +49 (0)3841 220 052 2 .: E-Mail: info@itg-wismar.de **www.itg-wismar.de**

TECHNICAL DRAWING

Sensor	ITG Part number	Color		Electrical pin assignment	
		Cap	Housing	Pin 1	Pin 2
D-10	410060	black	black	minus (-)	plus(+)





Dimension unit: mm
Dimension tolerances: linear ±0.5 mm , diameter ±0.3 mm

IT Dr. Gambert GmbH .: Hinter dem Chor 21 .: 23966 Wismar .: Germany
Phone: +49 (0)3841 220 050 .: Fax: +49 (0)3841 220 052 2 .: E-Mail: info@itg-wismar.de **www.itg-wismar.de**